



# State of Louisiana

Department of Health and Hospitals  
Office of Public Health

## NOTIFICATION FOR RESCISSION OF BOIL ADVISORY NATCHITOCHEs WATER SYSTEM (PWS ID 1069007)

June 8, 2016 (1:30 PM)

The Louisiana Department of Health and Hospitals/Office of Public Health, hereby rescinds the **BOIL ADVISORY** issued by Natchitoches Water System. The sample collected on June 7, 2016 cleared.

NOTIFIED BY:

A handwritten signature in black ink, appearing to read "Zahira Tieso".

Zahira Tieso, E.I.

Regional Engineer  
DHH-OPH-Region VII

RECEIVED BY:

\_\_\_\_\_  
Water Supply Representative

\_\_\_\_\_  
Title



State of Louisiana  
Department of Health & Hospitals  
Public Health Laboratories  
1035 Creswell Ave.  
Shreveport, LA 71101



June 08, 2016

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

**Sample Pt. Description:**

**Sample Pt ID:**

PWS ID: LA1069007  
Water System Name: NATCHITOCHEs WATER SYSTEM  
Facility ID:  
Free Chlorine Residual (mg/L):  
Total Chlorine Residual (mg/L): 1.1

Sample ID: S1600166-001  
Sample Type: Boil Advisory  
Sample Collector: Glenn Rainey  
Collection date: 6/7/2016 8:00:00AM  
Lab Submittal date: 6/7/2016 3:07:00PM

Component Name	Results	Units	MCL
<b>Coliforms - Presence/Absence</b>			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Sample Comments:

Additional Comments  
St. Mark Church @ Posey Road

Reviewed by: Melissa Jones